


Permit Reference Number : PPC/A/1157446

Operator : Kanadevia Inova UK Operations Ltd

Installation: Earlsgate Energy Center

Form Number: Air 1 (A1)

Reporting of Continuously Monitored Emissions to Air for Particulates mg/Nm3 at Emission Point A1 For the month of January 2025



	Monthly summary		Date	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31
Half-hourly average			Half-hourly average ELV	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0
	Monthly maximum	0.2	Maximum Half-hourly average	0.2	0.1	0.1	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	Off	Off	Off	Off	0.2	0.2	0.2	0.2	0.2	Off	0.2	0.2	0.2
	Monthly mean	0.1	Mean Half-hourly average	0.1	0.1	0.1	0.1	0.1	0.2	0.2	0.2	0.2	0.1	0.1	0.1	0.1	0.2	0.2	0.1	0.2	0.2	Off	Off	Off	Off	0.2	0.2	0.2	0.1	0.2	Off	0.1	0.2	0.2
	Monthly minimum	0.1	Minimum Half-hourly average	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	Off	Off	Off	Off	0.1	0.1	0.1	0.1	0.2	Off	0.1	0.1	0.1
	Total Invalid results	0	No of Invalid results	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
	Sum of exceedances	0	No of exceedances of ELV	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Off	Off	Off	Off	0	0	0	0	0	Off	0	0	0
Daily average			Daily average ELV	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	
	Monthly maximum	0.2	Daily average	0.1	0.1	0.1	0.1	0.1	0.2	0.2	0.2	0.2	0.1	0.1	0.1	0.1	0.2	0.2	0.1	0.2	0.2	Off	Off	Off	Off	0.2	0.2	0.2	0.1	0.2	Off	0.1	0.2	0.2
	No of invalid days	0	Value Valid?	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	
	Sum of exceedances	0	Value Exceeds ELV?	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	

Signed.....REDACTED.....

Date.....07.02.2025.....

(Authorised to sign as a representative of the Operator)


Permit Reference Number : PPC/A/1157446

Operator : Kanadevia Inova UK Operations Ltd

Installation: Earlsgate Energy Center

Form Number: Air 2 (A1)

Reporting of Continuously Monitored Emissions to Air for TOC mg/Nm3 at Emission Point A1 For the month of January 2025



Monthly summary			Date	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31
Half-hourly average			Half-hourly average ELV	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0
	Monthly maximum	5.7	Maximum Half-hourly average	1.6	1.7	4.1	3.1	3.3	1.6	3.3	1.6	1.4	2.1	2.0	1.3	5.2	3.9	2.0	2.1	3.6	2.2	Off	Off	Off	Off	5.2	5.7	3.8	2.0	3.5	Off	4.0	4.6	3.7
	Monthly mean	1.6	Mean Half-hourly average	1.2	1.3	1.6	1.8	1.7	1.1	1.0	1.2	1.0	1.2	1.2	0.9	1.1	1.1	1.1	1.0	1.4	1.6	Off	Off	Off	Off	2.5	1.7	2.1	1.5	3.5	Off	2.7	2.4	2.2
	Monthly minimum	0.0	Minimum Half-hourly average	0.9	1.0	0.6	0.7	1.1	0.6	0.6	0.6	0.5	0.5	0.6	0.7	0.5	0.5	0.7	0.0	0.6	0.6	Off	Off	Off	Off	0.9	0.4	0.9	0.4	3.5	Off	1.7	1.1	1.2
	Total Invalid results	0	No of Invalid results	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of exceedances	0	No of exceedances of ELV	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Off	Off	Off	Off	0	0	0	0	0	Off	0	0	0
Daily average			Daily average ELV	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
	Monthly maximum	3.5	Daily average	1.2	1.3	1.6	1.8	1.7	1.1	1.0	1.2	1.0	1.2	1.2	0.9	1.1	1.1	1.1	1.0	1.4	1.6	Off	Off	Off	Off	2.5	1.7	2.1	1.5	3.5	Off	2.7	2.4	2.2
	No of invalid days	0	Value Valid?	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y
	Sum of exceedances	0	Value Exceeds ELV?	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N

Signed.....REDACTED.....

Date.....07.02.2025.....

(Authorised to sign as a representative of the Operator)


Permit Reference Number : PPC/A/1157446

Operator : Kanadevia Inova UK Operations Ltd

Installation: Earlsgate Energy Center

Form Number: Air 3 (A1)

Reporting of Continuously Monitored Emissions to Air for HCl mg/Nm3 at Emission Point A1 For the month of January 2025



	Monthly summary		Date	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	
Half-hourly average			Half-hourly average ELV	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	
	Monthly maximum	7.6	Maximum Half-hourly average	7.2	7.2	7.3	7.2	7.1	7.0	7.1	6.8	6.7	6.9	7.0	7.0	7.6	7.0	6.3	7.4	6.8	7.1	Off	Off	Off	Off	Off	4.7	6.4	3.8	5.0	2.5	Off	2.7	3.8	4.1
	Monthly mean	4.8	Mean Half-hourly average	6.2	6.5	6.3	5.6	5.1	6.1	5.7	5.6	4.7	5.1	5.1	5.6	6.3	5.5	5.6	6.1	4.8	5.7	Off	Off	Off	Off	Off	3.7	3.4	3.1	3.7	2.5	Off	2.2	2.4	2.5
	Monthly minimum	1.8	Minimum Half-hourly average	5.2	5.9	4.9	4.5	4.0	5.0	4.0	4.2	3.9	3.6	4.0	3.2	5.0	4.4	5.1	5.0	3.7	4.7	Off	Off	Off	Off	Off	2.9	2.2	2.5	2.6	2.5	Off	1.9	1.8	1.9
	Total Invalid results	0	No of Invalid results	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
	Sum of exceedances	0	No of exceedances of ELV	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Off	Off	Off	Off	Off	0	0	0	0	0	Off	0	0	0
Daily average			Daily average ELV	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	
	Monthly maximum	6.5	Daily average	6.2	6.5	6.3	5.6	5.1	6.1	5.7	5.6	4.7	5.1	5.1	5.6	6.3	5.5	5.6	6.1	4.8	5.7	Off	Off	Off	Off	Off	3.7	3.4	3.1	3.7	2.5	Off	2.2	2.4	2.5
	No of invalid days	0	Value Valid?	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	
	Sum of exceedances	0	Value Exceeds ELV?	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N

Signed.....REDACTED.....

Date.....07.02.2025.....


(Authorised to sign as a representative of the Operator)

Permit Reference Number : PPC/A/1157446

Operator : Kanadevia Inova UK Operations Ltd

Installation: Earlsgate Energy Center

Form Number: Air 4 (A1)

Reporting of Continuously Monitored Emissions to Air for CO mg/Nm3 at Emission Point A1 For the month of January 2025

Monthly summary			Date	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31
10 Minute average			10 Minute average ELV (95th Percentile)	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150
	Monthly Maximum 10-min	683	Maximum 10 Minute average	16	8	472	99	128	12	414	61	160	227	49	46	583	683	49	358	410	446	Off	Off	Off	Off	97	316	224	181	443	Off	191	20	102
	Monthly mean 10-min avgs	6	95th Percentile	2	2	5	6	4	3	6	11	20	17	7	9	29	7	4	24	77	3	Off	Off	Off	Off	9	42	9	26	0	Off	7	7	7
	Monthly Minimum 10-min	0	Minimum 10 Minute average	0	0	0	1	1	0	1	1	1	2	1	0	1	1	0	1	0	Off	Off	Off	Off	2	1	2	1	5	Off	3	2	2	
	Total Invalid results	2	No of Invalid results	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	2	0	0	0	0	0	0	0	0
			Number of results above 150mg/m³	0	0	1	0	0	0	1	0	1	1	0	0	2	2	0	1	2	1	Off	Off	Off	Off	0	3	2	1	2	Off	1	0	0
	Sum of Exceedances of 95th percentile ELV	0	95th Percentile ELV Exceeded (Y/N)	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N
Daily average			Daily average ELV	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50
	Monthly maximum	280	Daily average	2	1	5	4	4	2	6	5	7	8	4	3	10	10	3	7	12	26	Off	Off	Off	Off	5	12	7	6	280	Off	9	5	5
	No of invalid days	0	Value Valid?	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y
	Sum of exceedances	1	Value Exceeds ELV? (Y/N)	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	Y	N	N	N	N

Signed..... REDACTED

Date..... 07.02.2025

(Authorised to sign as a representative of the Operator)

Environment Agency explanatory note: The 10-minute average ELV is based on the "95th percentile" In this case this means that 95% of the 10 minute averages in the calendar day (= 137) must be below 150 mg/m3, and 5% (= 7) are allowed to be any value above 150 mg/m3. Whilst we expect operators to minimise CO emissions at all times, it is perfectly acceptable for the value of the maximum 10-minute average to be above 150 mg/m3, provided the 95th percentile ELV has been met for that period


Permit Reference Number : PPC/A/1157446

Operator : Kanadevia Inova UK Operations Ltd

Installation: Earlsgate Energy Center

Form Number: Air 5 (A1)

Reporting of Continuously Monitored Emissions to Air for SO2 mg/Nm3 at Emission Point A1 For the month of January 2025



	Monthly summary		Date	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31
Half-hourly average			Half-hourly average ELV	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200
	Monthly maximum	42	Maximum Half-hourly average	5	7	7	9	10	9	10	10	13	12	15	8	7	7	7	7	9	9	Off	Off	Off	Off	20	42	15	19	5	Off	13	30	35
	Monthly mean	7	Mean Half-hourly average	4	5	5	6	7	7	6	7	7	7	7	5	5	4	3	3	4	6	Off	Off	Off	Off	10	18	11	13	5	Off	9	12	10
	Monthly minimum	2	Minimum Half-hourly average	2	3	4	4	5	5	4	6	5	5	5	3	3	2	2	2	3	2	Off	Off	Off	Off	7	11	7	7	5	Off	7	7	6
	Total Invalid results	0	No of Invalid results	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of exceedances	0	No of exceedances of ELV	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Off	Off	Off	Off	0	0	0	0	0	Off	0	0	0
Daily average			Daily average ELV	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40
	Monthly maximum	18	Daily average	4	5	5	6	7	7	6	7	7	7	7	5	5	4	3	3	4	6	Off	Off	Off	Off	10	18	11	13	5	Off	9	12	10
	No of invalid days	0	Value Valid?	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	
	Sum of exceedances	0	Value Exceeds ELV?	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N

Signed.....REDACTED.....

Date.....07.02.2025.....

(Authorised to sign as a representative of the Operator)


Permit Reference Number : PPC/A/1157446

Operator : Kanadevia Inova UK Operations Ltd

Installation: Earlsgate Energy Center

Form Number: Air 6 (A1)

Reporting of Continuously Monitored Emissions to Air for NO_x mg/Nm³ at Emission Point A1 For the month of January 2025



	Monthly summary		Date	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31
Half-hourly average			Half-hourly average ELV	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400
	Monthly maximum	204	Maximum Half-hourly average	160	161	163	166	160	161	167	167	166	168	171	165	179	186	178	170	204	171	Off	Off	Off	Off	185	177	176	180	114	Off	165	166	174
	Monthly mean	150	Mean Half-hourly average	151	152	152	152	152	152	152	152	152	153	152	151	153	151	152	152	152	151	Off	Off	Off	Off	153	150	153	150	114	Off	154	152	152
	Monthly minimum	105	Minimum Half-hourly average	138	141	141	139	142	140	139	140	136	138	128	119	128	110	119	133	130	140	Off	Off	Off	Off	120	105	115	108	114	Off	137	130	114
	Total Invalid results	0	No of Invalid results	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
	Sum of exceedances	0	No of exceedances of ELV	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Off	Off	Off	Off	0	0	0	0	0	Off	0	0	0
Daily average			Daily average ELV	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	
	Monthly maximum	154	Daily average	151	152	152	152	152	152	152	152	152	153	152	151	153	151	152	152	152	151	Off	Off	Off	Off	153	150	153	150	114	Off	154	152	152
	No of invalid days	0	Value Valid?	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	
	Sum of exceedances	0	Value Exceeds ELV?	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N

Signed.....REDACTED.....

Date.....07.02.2025.....

(Authorised to sign as a representative of the Operator)


Permit Reference Number : PPC/A/1157446

Operator : Kanadevia Inova UK Operations Ltd

Installation: Earlsgate Energy Center

Form Number: Air 7 (A1)

Reporting of Continuously Monitored Emissions to Air for NH3 mg/Nm3 at Emission Point A1 For the month of January 2025



Signed.....REDACTED.....

Date.....07.02.2025.....

(Authorised to sign as a representative of the Operator)


Permit Reference Number : PPC/A/1157446

Operator : Kanadevia Inova UK Operations Ltd

Installation: Earlsgate Energy Center

Form Number: Air 8 (A1)

Reporting of Continuously Monitored Emissions to Air for N2O mg/Nm3 at Emission Point A1 For the month of January 2025



	Monthly summary		Date	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31
Half-hourly average			Half-hourly average ELV	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	Monthly maximum	23.6	Maximum Half-hourly average	8.2	7.2	8.2	8.7	10.0	12.0	7.5	7.0	5.3	5.5	6.6	10.8	10.8	12.3	15.5	8.2	9.3	21.2	Off	Off	Off	Off	9.0	10.8	7.8	9.6	23.6	Off	9.6	5.5	7.7
	Monthly mean	5.7	Mean Half-hourly average	5.3	4.9	5.2	5.2	6.4	8.3	5.9	4.2	3.5	3.0	4.2	4.4	7.0	6.5	4.7	4.7	5.8	7.6	Off	Off	Off	Off	4.7	5.6	3.4	3.7	23.6	Off	3.6	3.1	3.5
	Monthly minimum	0.2	Minimum Half-hourly average	3.7	3.4	2.1	3.3	3.6	5.0	3.5	2.2	2.0	1.6	1.3	0.2	1.9	2.0	1.7	2.0	1.5	4.2	Off	Off	Off	Off	2.5	2.0	1.0	1.4	23.6	Off	0.9	1.0	0.8
	Total Invalid results	0	No of Invalid results	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of exceedances	0	No of exceedances of ELV	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Off	Off	Off	Off	N/A	N/A	N/A	N/A	N/A	Off	N/A	N/A
Daily average			Daily average ELV	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	Monthly maximum	23.6	Daily average	5.3	4.9	5.2	5.2	6.4	8.3	5.9	4.2	3.5	3.0	4.2	4.4	7.0	6.5	4.7	4.7	5.8	7.6	Off	Off	Off	Off	4.7	5.6	3.4	3.7	23.6	Off	3.6	3.1	3.5
	No of invalid days	0	Value Valid?	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	
	Sum of exceedances	0	Value Exceeds ELV?	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N

Signed.....REDACTED.....

Date.....07.02.2025.....

(Authorised to sign as a representative of the Operator)


Permit Reference Number : PPC/A/1157446

Operator : Kanadevia Inova UK Operations Ltd

Installation: Earlsgate Energy Center

Form Number: Air A (A1)

Reporting of Continuously Monitored Emissions to Air for CO2 % at Emission Point A1 For the month of January 2025



	Monthly summary		Date	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	
Half-hourly average			Half-hourly average ELV	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	Monthly maximum	9	Maximum Half-hourly average	9	9	9	8	8	8	8	9	9	9	9	9	9	9	9	9	9	9	Off	Off	Off	Off	9	8	8	8	7	Off	9	9	9	
	Monthly mean	8	Mean Half-hourly average	8	8	8	8	8	8	8	8	8	9	9	9	9	9	9	9	9	8	Off	Off	Off	Off	8	8	8	8	7	Off	8	9	9	
	Monthly minimum	7	Minimum Half-hourly average	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	7	Off	Off	Off	Off	8	8	8	8	7	Off	8	8	8	
	Total Invalid results	0	No of Invalid results	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
	Sum of exceedances	0	No of exceedances of ELV	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Off	Off	Off	Off	N/A	N/A	N/A	N/A	N/A	N/A	Off	N/A	N/A	N/A
Daily average			Daily average ELV	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	Monthly maximum	9	Daily average	8	8	8	8	8	8	8	8	9	9	9	9	9	9	9	9	9	8	Off	Off	Off	Off	8	8	8	8	7	Off	8	9	9	
	No of invalid days	0	Value Valid?	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	
	Sum of exceedances	0	Value Exceeds ELV?	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N

Signed.....REDACTED.....

Date.....07.02.2025.....

(Authorised to sign as a representative of the Operator)


Permit Reference Number : PPC/A/1157446

Operator : Kanadevia Inova UK Operations Ltd

Installation: Earlsgate Energy Center

Form Number: Air B (A1)

Reporting of Continuously Monitored Emissions to Air for Dry Oxygen % at Emission Point A1 For the month of January 2025



	Monthly summary		Date	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	
Half-hourly average			Half-hourly average ELV	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	Monthly maximum	11	Maximum Half-hourly average	8	8	8	8	8	8	8	8	7	7	7	7	8	8	8	9	8	8	11	Off	Off	Off	Off	9	8	7	8	10	Off	8	7	7
	Monthly mean	7	Mean Half-hourly average	8	8	8	8	8	8	8	7	7	7	7	7	7	7	7	7	7	7	8	Off	Off	Off	Off	7	7	7	7	10	Off	7	7	7
	Monthly minimum	5	Minimum Half-hourly average	7	7	7	7	7	7	7	7	7	6	7	5	7	7	7	7	7	7	Off	Off	Off	Off	7	7	7	6	10	Off	6	6	6	
	Total Invalid results	0	No of Invalid results	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
	Sum of exceedances	0	No of exceedances of ELV	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Off	Off	Off	Off	N/A	N/A	N/A	N/A	N/A	Off	N/A	N/A	N/A
Daily average			Daily average ELV	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	Monthly maximum	10	Daily average	8	8	8	8	8	8	8	7	7	7	7	7	7	7	7	7	7	8	Off	Off	Off	Off	7	7	7	7	10	Off	7	7	7	
	No of invalid days	0	Value Valid?	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	
	Sum of exceedances	0	Value Exceeds ELV?	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N

Signed.....REDACTED.....

Date.....07.02.2025.....

(Authorised to sign as a representative of the Operator)


Permit Reference Number : PPC/A/1157446

Operator : Kanadevia Inova UK Operations Ltd

Installation: Earlsgate Energy Center

Form Number: Air C (A1)

Reporting of Continuously Monitored Emissions to Air for Moisture % at Emission Point A1 For the month of January 2025



	Monthly summary		Date	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31
Half-hourly average			Half-hourly average ELV	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	Monthly maximum	25	Maximum Half-hourly average	21	20	24	21	19	20	21	22	22	21	23	24	22	21	23	25	22	20	Off	Off	Off	Off	20	22	20	22	12	Off	22	23	22
	Monthly mean	19	Mean Half-hourly average	19	19	19	19	18	18	19	19	19	19	19	20	20	20	20	20	19	18	Off	Off	Off	Off	17	18	18	19	12	Off	21	20	20
	Monthly minimum	11	Minimum Half-hourly average	18	18	17	16	17	16	16	17	16	17	16	18	17	18	16	18	17	11	Off	Off	Off	Off	15	15	17	17	12	Off	20	17	16
	Total Invalid results	0	No of Invalid results	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
	Sum of exceedances	0	No of exceedances of ELV	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Off	Off	Off	Off	N/A	N/A	N/A	N/A	N/A	Off	N/A	N/A	N/A
Daily average			Daily average ELV	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	Monthly maximum	21	Daily average	19	19	19	19	18	18	19	19	19	19	19	20	20	20	20	20	19	18	Off	Off	Off	Off	17	18	18	19	12	Off	21	20	20
	No of invalid days	0	Value Valid?	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	
	Sum of exceedances	0	Value Exceeds ELV?	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N

Signed.....REDACTED.....

Date.....07.02.2025.....

(Authorised to sign as a representative of the Operator)