


Permit Reference Number : PPC/A/1157446

Operator : Kanadevia Inova UK Operations Ltd

Installation: Earlsgate Energy Center

Form Number: Air 3 (A1)

Reporting of Continuously Monitored Emissions to Air for HCl mg/Nm3 at Emission Point A1 For the month of May 2025



	Monthly summary		Date	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31
Half-hourly average			Half-hourly average ELV	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0
	Monthly maximum	62.6	Maximum Half-hourly average	7.9	7.4	7.4	7.4	7.3	7.4	7.3	7.3	7.5	7.4	7.5	7.5	7.5	9.0	62.6	3.7	6.7	7.5	7.5	7.5	7.8	7.4	7.4	7.4	7.4	7.2	7.4	7.4	7.4	7.8	7.6
	Monthly mean	6.4	Mean Half-hourly average	6.6	6.0	6.7	6.8	6.5	6.8	6.7	6.8	6.7	6.7	7.0	6.7	6.1	5.6	8.5	2.9	3.8	6.8	6.6	6.7	6.7	6.6	6.5	6.7	6.9	6.3	6.2	6.8	6.7	6.8	6.4
	Monthly minimum	2.1	Minimum Half-hourly average	5.4	4.9	5.2	5.9	5.4	5.7	5.6	5.9	5.6	6.1	6.2	5.3	4.6	3.7	3.4	2.1	2.2	5.4	5.7	5.9	5.7	5.2	5.5	6.0	6.0	5.6	5.2	5.9	5.5	5.6	5.6
	Total Invalid results	0	No of Invalid results	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of exceedances	1	No of exceedances of ELV	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Daily average			Daily average ELV	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0
	Monthly maximum	8.5	Daily average	6.6	6.0	6.7	6.8	6.5	6.8	6.7	6.8	6.7	6.7	7.0	6.7	6.1	5.6	8.5	2.9	3.8	6.8	6.6	6.7	6.7	6.6	6.5	6.7	6.9	6.3	6.2	6.8	6.7	6.8	6.4
	No of invalid days	0	Value Valid?	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	
	Sum of exceedances	1	Value Exceeds ELV?	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	Y	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N

Signed.....REDACTED.....

Date.....04/06/2025.....

(Authorised to sign as a representative of the Operator)


Permit Reference Number : PPC/A/1157446

Operator : Kanadevia Inova UK Operations Ltd

Installation: Earlsgate Energy Center

Form Number: Air 5 (A1)

Reporting of Continuously Monitored Emissions to Air for SO₂ mg/Nm³ at Emission Point A1 For the month of May 2025



	Monthly summary		Date	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31
Half-hourly average			Half-hourly average ELV	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200
	Monthly maximum	81	Maximum Half-hourly average	8	8	7	8	7	7	6	7	7	8	7	11	11	18	81	12	19	6	6	7	6	6	9	7	8	9	8	8	7	7	7
	Monthly mean	6	Mean Half-hourly average	5	5	5	5	5	5	5	5	5	6	6	6	7	8	10	5	6	4	5	5	5	5	6	6	6	7	6	6	6	5	5
	Monthly minimum	0	Minimum Half-hourly average	4	4	4	4	4	4	4	5	4	5	5	5	5	4	4	0	4	0	3	4	3	3	4	4	4	5	5	2	4	4	4
	Total Invalid results	0	No of Invalid results	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of exceedances	0	No of exceedances of ELV	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Daily average			Daily average ELV	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40
	Monthly maximum	10	Daily average	5	5	5	5	5	5	5	5	5	6	6	6	7	8	10	5	6	4	5	5	5	5	6	6	6	7	6	6	6	5	5
	No of invalid days	0	Value Valid?	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	
	Sum of exceedances	0	Value Exceeds ELV?	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N

Signed.....REDACTED.....

Date.....04/06/2025.....

(Authorised to sign as a representative of the Operator)


Permit Reference Number : PPC/A/1157446

Operator : Kanadevia Inova UK Operations Ltd

Installation: Earlsgate Energy Center

Form Number: Air 6 (A1)

Reporting of Continuously Monitored Emissions to Air for NOx mg/Nm3 at Emission Point A1 For the month of May 2025



Monthly summary			Date	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31
Half-hourly average			Half-hourly average ELV	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400	400
	Monthly maximum	194	Maximum Half-hourly average	178	190	165	145	146	142	132	129	137	113	122	148	110	112	141	168	157	163	176	169	162	166	164	184	172	176	170	194	170	175	174
	Monthly mean	133	Mean Half-hourly average	145	142	136	136	136	134	120	120	105	104	104	105	97	96	101	100	119	152	153	152	152	152	152	152	152	152	153	151	152	154	152
	Monthly minimum	53	Minimum Half-hourly average	105	100	104	124	124	115	109	110	89	92	93	93	83	79	80	53	57	143	130	137	134	132	137	108	121	127	138	107	94	141	138
	Total Invalid results	0	No of Invalid results	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of exceedances	0	No of exceedances of ELV	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Daily average			Daily average ELV	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180
	Monthly maximum	154	Daily average	145	142	136	136	136	134	120	120	105	104	104	105	97	96	101	100	119	152	153	152	152	152	152	152	152	152	153	151	152	154	152
	No of invalid days	0	Value Valid?	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y
	Sum of exceedances	0	Value Exceeds ELV?	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N

Signed.....REDACTED.....

Date.....04/06/2025.....

(Authorised to sign as a representative of the Operator)


Permit Reference Number : PPC/A/1157446

Operator : Kanadevia Inova UK Operations Ltd

Installation: Earlsgate Energy Center

Form Number: Air 2 (A1)

Reporting of Continuously Monitored Emissions to Air for TOC mg/Nm3 at Emission Point A1 For the month of May 2025



	Monthly summary		Date	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31
Half-hourly average			Half-hourly average ELV	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0
	Monthly maximum	49.7	Maximum Half-hourly average	2.2	3.7	2.0	1.5	2.2	3.1	2.8	1.4	2.2	2.2	1.8	2.0	3.4	3.4	49.7	4.5	3.7	3.7	4.7	5.7	6.2	3.6	4.2	4.1	3.4	3.0	3.8	3.6	4.0	4.1	5.1
	Monthly mean	2.1	Mean Half-hourly average	0.6	0.9	0.5	0.7	1.0	1.7	1.3	0.8	0.9	1.1	1.1	1.0	1.8	2.3	5.9	2.8	2.5	2.4	2.4	3.2	3.5	2.6	2.8	3.1	2.7	2.1	2.6	2.7	2.5	2.5	2.7
	Monthly minimum	0.0	Minimum Half-hourly average	0.0	0.0	0.0	0.1	0.3	0.0	0.4	0.5	0.2	0.3	0.4	0.4	0.2	1.0	1.6	1.5	1.6	1.1	1.5	1.8	1.6	1.6	2.0	2.3	2.0	1.2	1.5	1.9	1.6	1.5	1.7
	Total Invalid results	0	No of Invalid results	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of exceedances	2	No of exceedances of ELV	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Daily average			Daily average ELV	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
	Monthly maximum	5.9	Daily average	0.6	0.9	0.5	0.7	1.0	1.7	1.3	0.8	0.9	1.1	1.1	1.0	1.8	2.3	5.9	2.8	2.5	2.4	2.4	3.2	3.5	2.6	2.8	3.1	2.7	2.1	2.6	2.7	2.5	2.5	2.7
	No of invalid days	0	Value Valid?	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y
	Sum of exceedances	0	Value Exceeds ELV?	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N

Signed.....REDACTED.....

Date.....04/06/2025.....

(Authorised to sign as a representative of the Operator)


Permit Reference Number : PPC/A/1157446

Operator : Kanadevia Inova UK Operations Ltd

Installation: Earlsgate Energy Center

Form Number: Air 7 (A1)

Reporting of Continuously Monitored Emissions to Air for NH3 mg/Nm3 at Emission Point A1 For the month of May 2025



Monthly summary			Date	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31
Half-hourly average			Half-hourly average ELV	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	Monthly maximum	9.1	Maximum Half-hourly average	0.7	0.6	0.5	0.5	0.9	0.7	1.1	1.7	2.4	2.4	2.3	3.0	4.4	4.2	9.1	5.6	4.2	1.0	0.8	0.5	0.6	0.5	0.5	0.3	0.7	0.8	0.8	0.6	0.6	0.5	0.5
	Monthly mean	0.9	Mean Half-hourly average	0.4	0.3	0.3	0.3	0.5	0.4	0.8	1.0	1.5	1.6	1.7	1.8	2.3	2.4	2.5	2.8	1.9	0.5	0.4	0.3	0.3	0.3	0.3	0.2	0.3	0.5	0.4	0.4	0.3	0.3	0.3
	Monthly minimum	0.1	Minimum Half-hourly average	0.2	0.1	0.2	0.2	0.3	0.3	0.4	0.6	1.0	1.1	1.2	1.3	1.3	1.0	1.5	1.4	0.4	0.3	0.2	0.1	0.1	0.1	0.1	0.1	0.2	0.3	0.2	0.1	0.2	0.2	0.1
	Total Invalid results	0	No of Invalid results	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of exceedances	0	No of exceedances of ELV	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Daily average			Daily average ELV	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
	Monthly maximum	2.8	Daily average	0.4	0.3	0.3	0.3	0.5	0.4	0.8	1.0	1.5	1.6	1.7	1.8	2.3	2.4	2.5	2.8	1.9	0.5	0.4	0.3	0.3	0.3	0.3	0.2	0.3	0.5	0.4	0.4	0.3	0.3	0.3
	No of invalid days	0	Value Valid?	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y
	Sum of exceedances	0	Value Exceeds ELV?	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N

Signed.....REDACTED.....

Date.....04/06/2025.....

(Authorised to sign as a representative of the Operator)


Permit Reference Number : PPC/A/1157446

Operator : Kanadevia Inova UK Operations Ltd

Installation: Earlsgate Energy Center

Form Number: Air 1 (A1)

Reporting of Continuously Monitored Emissions to Air for Particulates mg/Nm3 at Emission Point A1 For the month of May 2025



	Monthly summary		Date	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	
Half-hourly average			Half-hourly average ELV	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	
	Monthly maximum	0.4	Maximum Half-hourly average	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.2	0.1	0.4	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.2	0.1	0.1	0.2	0.2	0.1	0.1	0.1	0.1
	Monthly mean	0.1	Mean Half-hourly average	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.2	0.1	0.1	0.1	0.1	0.1
	Monthly minimum	0.1	Minimum Half-hourly average	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1
	Total Invalid results	0	No of Invalid results	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of exceedances	0	No of exceedances of ELV	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Daily average			Daily average ELV	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0
	Monthly maximum	0.2	Daily average	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.2	0.1	0.1	0.1	0.1	0.1	0.1
	No of invalid days	0	Value Valid?	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y
	Sum of exceedances	0	Value Exceeds ELV?	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N

Signed.....REDACTED.....

Date.....04/06/2025.....

(Authorised to sign as a representative of the Operator)


Permit Reference Number : PPC/A/1157446

Operator : Kanadevia Inova UK Operations Ltd

Installation: Earlsgate Energy Center

Form Number: Air 8 (A1)

Reporting of Continuously Monitored Emissions to Air for N2O mg/Nm3 at Emission Point A1 For the month of May 2025



	Monthly summary		Date	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	
Half-hourly average			Half-hourly average ELV	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	Monthly maximum	53.3	Maximum Half-hourly average	9.9	9.2	5.4	5.0	10.3	10.0	10.0	11.7	13.7	13.5	13.0	15.0	20.3	19.9	53.3	10.8	9.6	5.3	8.1	11.4	8.4	7.4	13.2	8.0	13.8	13.9	13.5	11.3	9.5	8.8	8.9	
	Monthly mean	6.6	Mean Half-hourly average	2.7	3.0	3.4	3.5	6.2	6.7	7.8	9.0	9.1	9.7	9.9	10.5	11.0	10.8	9.3	6.1	5.5	3.9	4.7	5.0	4.7	5.1	7.0	5.0	6.1	8.2	7.0	6.0	6.1	5.3	5.7	
	Monthly minimum	0.1	Minimum Half-hourly average	0.1	0.1	0.4	1.5	1.7	4.7	6.1	7.1	3.4	7.5	6.8	7.2	7.5	6.3	0.9	1.3	1.1	2.2	2.1	2.6	2.3	3.4	3.9	0.9	4.2	5.4	3.7	2.4	3.2	3.4	4.1	
	Total Invalid results	0	No of Invalid results	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
	Sum of exceedances	0	No of exceedances of ELV	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Daily average			Daily average ELV	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	Monthly maximum	11.0	Daily average	2.7	3.0	3.4	3.5	6.2	6.7	7.8	9.0	9.1	9.7	9.9	10.5	11.0	10.8	9.3	6.1	5.5	3.9	4.7	5.0	4.7	5.1	7.0	5.0	6.1	8.2	7.0	6.0	6.1	5.3	5.7	
	No of invalid days	0	Value Valid?	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	
	Sum of exceedances	0	Value Exceeds ELV?	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N

Signed.....REDACTED.....

Date.....04/06/2025.....


(Authorised to sign as a representative of the Operator)

Permit Reference Number : PPC/A/1157446

Operator : Kanadevia Inova UK Operations Ltd

Installation: Earlsgate Energy Center

Form Number: Air 4 (A1)

Reporting of Continuously Monitored Emissions to Air for CO mg/Nm3 at Emission Point A1 For the month of May 2025

Monthly summary			Date	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31
10 Minute average			10 Minute average ELV (95th Percentile)	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150
	Monthly Maximum 10-min	1326	Maximum 10 Minute average	41	56	506	213	201	34	15	96	233	88	66	205	607	153	1326	113	212	33	512	517	33	32	180	26	75	173	52	126	348	571	340
	Monthly mean 10-min avgs	8	95th Percentile	6	7	7	3	4	5	4	19	8	6	7	5	7	14	574	7	33	5	14	14	8	7	7	6	5	7	6	12	6	17	13
	Monthly Minimum 10-min	0	Minimum 10 Minute average	0	2	0	0	0	1	1	1	1	1	1	0	1	1	0	1	1	1	1	2	1	1	2	3	0	1	2	2	1	2	1
	Total Invalid results	2	No of Invalid results	0	0	0	0	0	0	0	0	0	0	0	0	2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
			Number of results above 150mg/m³	0	0	1	1	1	0	0	0	1	0	0	1	1	1	16	0	1	0	2	2	0	0	1	0	0	1	0	0	1	2	3
	Sum of Exceedances of 95th percentile ELV	1	95th Percentile ELV Exceeded (Y/N)	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	Y	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N
Daily average			Daily average ELV	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50
	Monthly maximum	82	Daily average	4	5	7	3	3	3	3	5	5	4	4	4	9	7	82	5	7	3	12	11	5	5	7	5	5	6	5	7	6	12	11
	No of invalid days	0	Value Valid?	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	
	Sum of exceedances	1	Value Exceeds ELV? (Y/N)	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	Y	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N

Signed.....REDACTED.....

Date.....04/06/2025.....

(Authorised to sign as a representative of the Operator)

Environment Agency explanatory note: The 10-minute average ELV is based on the "95th percentile" In this case this means that 95% of the 10 minute averages in the calendar day (= 137) must be below 150 mg/m3, and 5% (= 7) are allowed to be any value above 150 mg/m3. Whilst we expect operators to minimise CO emissions at all times, it is perfectly acceptable for the value of the maximum 10-minute average to be above 150 mg/m3, provided the 95th percentile ELV has been met for that period


Permit Reference Number : PPC/A/1157446

Operator : Kanadevia Inova UK Operations Ltd

Installation: Earlsgate Energy Center

Form Number: Air A (A1)

Reporting of Continuously Monitored Emissions to Air for CO2 % at Emission Point A1 For the month of May 2025



	Monthly summary		Date	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	
Half-hourly average			Half-hourly average ELV	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	Monthly maximum	8	Maximum Half-hourly average	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	
	Monthly mean	8	Mean Half-hourly average	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	7	8	8	8	8	8	8	8	7	7	7	7	7	8	7	8	7
	Monthly minimum	4	Minimum Half-hourly average	7	8	8	8	8	8	8	8	8	8	8	8	8	8	8	4	8	8	8	7	7	7	8	7	7	7	7	7	7	7	7	
	Total Invalid results	0	No of Invalid results	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
	Sum of exceedances	0	No of exceedances of ELV	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Daily average			Daily average ELV	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	Monthly maximum	8	Daily average	8	8	8	8	8	8	8	8	8	8	8	8	8	8	7	8	8	8	8	8	8	8	7	7	7	7	7	8	7	8	7	
	No of invalid days	0	Value Valid?	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	
	Sum of exceedances	0	Value Exceeds ELV?	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N

Signed.....REDACTED.....

Date.....04/06/2025.....

(Authorised to sign as a representative of the Operator)


Permit Reference Number : PPC/A/1157446

Operator : Kanadevia Inova UK Operations Ltd

Installation: Earlsgate Energy Center

Form Number: Air B (A1)

Reporting of Continuously Monitored Emissions to Air for Dry Oxygen % at Emission Point A1 For the month of May 2025



	Monthly summary		Date	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	
Half-hourly average			Half-hourly average ELV	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	Monthly maximum	16	Maximum Half-hourly average	12	7	7	7	9	8	8	8	8	8	8	8	8	8	16	7	7	7	8	8	8	7	9	8	10	10	8	8	8	7	7	
	Monthly mean	7	Mean Half-hourly average	7	7	7	7	8	8	8	8	8	8	8	8	8	7	7	6	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	
	Monthly minimum	5	Minimum Half-hourly average	6	5	6	6	6	7	7	7	7	7	7	7	7	6	6	6	6	6	6	6	6	6	7	7	6	7	6	6	6	6	6	
	Total Invalid results	0	No of Invalid results	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
	Sum of exceedances	0	No of exceedances of ELV	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Daily average			Daily average ELV	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	Monthly maximum	8	Daily average	7	7	7	7	8	8	8	8	8	8	8	8	8	7	7	6	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	
	No of invalid days	0	Value Valid?	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	
	Sum of exceedances	0	Value Exceeds ELV?	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N

Signed.....REDACTED.....

Date.....04/06/2025.....

(Authorised to sign as a representative of the Operator)


Permit Reference Number : PPC/A/1157446

Operator : Kanadevia Inova UK Operations Ltd

Installation: Earlsgate Energy Center

Form Number: Air C (A1)

Reporting of Continuously Monitored Emissions to Air for Moisture % at Emission Point A1 For the month of May 2025



	Monthly summary		Date	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31
Half-hourly average			Half-hourly average ELV	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	Monthly maximum	23	Maximum Half-hourly average	20	21	21	20	20	19	20	21	20	20	19	21	20	20	22	22	20	23	21	21	20	20	18	19	19	20	20	20	20	20	19
	Monthly mean	17	Mean Half-hourly average	18	18	18	18	17	17	17	17	17	16	16	17	18	17	16	18	17	18	17	17	17	17	16	16	16	17	17	17	17	17	17
	Monthly minimum	3	Minimum Half-hourly average	11	16	16	16	14	15	16	14	16	14	15	15	15	15	3	15	16	17	14	14	14	15	12	14	12	14	14	15	15	14	14
	Total Invalid results	0	No of Invalid results	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of exceedances	0	No of exceedances of ELV	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Daily average			Daily average ELV	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	Monthly maximum	18	Daily average	18	18	18	18	17	17	17	17	17	16	16	17	18	17	16	18	17	18	17	17	17	17	16	16	16	17	17	17	17	17	17
	No of invalid days	0	Value Valid?	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	
	Sum of exceedances	0	Value Exceeds ELV?	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N

Signed.....REDACTED.....

Date.....04/06/2025.....

(Authorised to sign as a representative of the Operator)